

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

1/27/2022


Phone: (856) 840-8800
Fax: (856) 840-8815

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 1/13/2022. The results are tabulated on the attached data pages for the following client designated project:

21-353/ Harte Elem. School

The reference number for these samples is EMSL Order #012201007. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012201007

CustomerID: TTIE54

CustomerPO: 034036

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 1/13/2022 09:00 AM

Project: 21-353/ Harte Elem. School

Analytical Results

Client Sample Description 1-CH09-1-C-141A **Collected:** 1/13/2022 **Lab ID:** 012201007-0001
 Near Elevator 5:19:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/25/2022 KB	1/26/2022 KB 04:29

Client Sample Description 2-CH09-2-C-011A **Collected:** 1/13/2022 **Lab ID:** 012201007-0002
 Outside APR 5:06:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/25/2022 KB	1/26/2022 KB 04:30

Client Sample Description 3-CH09-2-S-01A **Collected:** 1/13/2022 **Lab ID:** 012201007-0003
 Kitchen 5:07:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.50	1.00 µg/L	1/25/2022 KB	1/26/2022 KB 04:32

Client Sample Description 4-CH09-2-NURA **Collected:** 1/13/2022 **Lab ID:** 012201007-0004
 Nurse 5:04:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.50	1.00 µg/L	1/25/2022 KB	1/26/2022 KB 04:33

Client Sample Description 5-CH09-2-C-15A **Collected:** 1/13/2022 **Lab ID:** 012201007-0005
 Room 204 5:03:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.24	1.00 µg/L	1/25/2022 KB	1/26/2022 KB 04:41

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012201007

CustomerID: TTIE54

CustomerPO: 034036

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 1/13/2022 09:00 AM

Project: 21-353/ Harte Elem. School

Analytical Results

Client Sample Description 6-CH09-2-C-16A
 Room 203 **Collected:** 1/13/2022 5:02:00 AM **Lab ID:** 012201007-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.4	1.00 µg/L	1/25/2022 KB	1/26/2022 KB 04:43

Client Sample Description 7-CH09-2-C-18A
 Room 201 **Collected:** 1/13/2022 5:00:00 AM **Lab ID:** 012201007-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.04	1.00 µg/L	1/25/2022 KB	1/26/2022 KB 04:44

Client Sample Description 8-CH09-1-C-02A
 Hall Across From Room 106 **Collected:** 1/13/2022 5:15:00 AM **Lab ID:** 012201007-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/25/2022 KB	1/26/2022 KB 04:46

Client Sample Description 9-CH09-2-C-14A
 Hall Across From Room 206 **Collected:** 1/13/2022 5:16:00 AM **Lab ID:** 012201007-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/25/2022 KB	1/26/2022 KB 04:47

Client Sample Description 10-CH09-1-C-BR1A
 New Addition Left **Collected:** 1/13/2022 5:17:00 AM **Lab ID:** 012201007-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/25/2022 KB	1/26/2022 KB 04:57

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012201007

CustomerID: TTIE54

CustomerPO: 034036

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 1/13/2022 09:00 AM

Project: 21-353/ Harte Elem. School

Analytical Results

Client Sample Description 11-CH09-1-C-BR2A **Collected:** 1/13/2022 **Lab ID:** 012201007-0011
 New Addition Right 5:18:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/25/2022 KB	1/26/2022 KB 05:01

Client Sample Description 12-CH09-FB **Collected:** 1/13/2022 **Lab ID:** 012201007-0012
 Blank 5:00:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/25/2022 KB	1/26/2022 KB 05:03

Client Sample Description 13-CH09-TLOUNGE **Collected:** 1/13/2022 **Lab ID:** 012201007-0013
 Teacher's Lounge 5:10:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.75	1.00 µg/L	1/25/2022 KB	1/26/2022 KB 05:04

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results