



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Tim Popp
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

2/2/2022

Phone: (856) 840-8800
Fax: (856) 840-8815

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 1/19/2022. The results are tabulated on the attached data pages for the following client designated project:

21-353/Stockton Elementary

The reference number for these samples is EMSL Order #012201060. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012201060

CustomerID: TTIE54

CustomerPO: 034036

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 1/19/2022 09:20 AM

Project: 21-353/Stockton Elementary

Analytical Results

Client Sample Description 1-CH33-1-C-01A
 KITCHEN **Collected:** 1/19/2022 5:32:00 AM **Lab ID:** 012201060-0001

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 1.37 | 1.00 µg/L | 1/25/2022 KB | 1/26/2022 JW 22:34 |

Client Sample Description 2-CH33-1-C-02A
 APR **Collected:** 1/19/2022 5:30:00 AM **Lab ID:** 012201060-0002

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 1/27/2022 KB | 1/31/2022 KB 19:23 |

Client Sample Description 3-CH33-1-C-S5A
 FACULTY LOUNGE **Collected:** 1/19/2022 5:34:00 AM **Lab ID:** 012201060-0003

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 1.36 | 1.00 µg/L | 1/27/2022 KB | 1/31/2022 KB 19:27 |

Client Sample Description 4-CH33-1-C-15A
 HALL NEAR ROOM 115 **Collected:** 1/19/2022 5:35:00 AM **Lab ID:** 012201060-0004

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 1/27/2022 KB | 1/31/2022 KB 19:29 |

Client Sample Description 5-CH33-1-C-S7A
 OLD NURSE/CST **Collected:** 1/19/2022 5:37:00 AM **Lab ID:** 012201060-0005

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 30.5 | 1.00 µg/L | 1/27/2022 KB | 1/31/2022 KB 19:31 |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012201060

CustomerID: TTIE54

CustomerPO: 034036

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 1/19/2022 09:20 AM

Project: 21-353/Stockton Elementary

Analytical Results

Client Sample Description 6-CH33-1-C-S9A
NURSE
Collected: 1/19/2022 5:47:00 AM
Lab ID: 012201060-0006

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 2.93 | 1.00 µg/L | 1/27/2022 KB | 1/31/2022 KB 19:35 |

Client Sample Description 7-CH30-1-C-09A
MAIN LOBBY
Collected: 1/19/2022 5:46:00 AM
Lab ID: 012201060-0007

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 1/27/2022 KB | 1/31/2022 KB 19:37 |

Client Sample Description 8-CH30-1-C-29LA
HALL ACROSS FROM ROOM 123
Collected: 1/19/2022 5:40:00 AM
Lab ID: 012201060-0008

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 1/27/2022 KB | 1/31/2022 KB 19:38 |

Client Sample Description 9-CH30-1-C-16HA
HALL ACROSS FROM 108
Collected: 1/19/2022 5:42:00 AM
Lab ID: 012201060-0009

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 1/27/2022 KB | 1/31/2022 KB 19:40 |

Client Sample Description 10-CH30-1-C-18A
ROOM 101
Collected: 1/19/2022 5:45:00 AM
Lab ID: 012201060-0010

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 2.12 | 1.00 µg/L | 1/27/2022 KB | 1/31/2022 KB 19:41 |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012201060

CustomerID: TTIE54

CustomerPO: 034036

ProjectID:

Attn: **Tim Popp**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 1/19/2022 09:20 AM

Project: 21-353/Stockton Elementary

Analytical Results

Client Sample Description 11-CH30-1-C-19A **Collected:** 1/19/2022 **Lab ID:** 012201060-0011
 ROOM 100 5:45:00 AM

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 1.85 | 1.00 µg/L | 1/27/2022 KB | 1/31/2022 KB 19:43 |

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results